



Job Name: _____

Job Location: _____

Contractor: _____


Engineer: _____

Approval: _____

Ball Valve Meter Bars

Design Features:

- Heavy One piece Cast Iron I-Beam Construction
- Black Finish
- Center Rear Inlet with Integral Valve for Manifold Use
- Top O-Ring Insulated Union Outlet
- With Tap
- ConEd Approved



Material Specifications			
No.	Part	Material	Spec Meets
1	Union Tail	ZP Yellow Dichromate Finished Steel	
2	Union Nut	Black Malleable Iron	ASTMA47
3	Tap	Steel	
4	Body	Black Cast Iron	ASTMA126 Class B
5	Valve Stem	Brass	
6	Meter Nut	Black Malleable Iron	ASTMA47
	Ball Valve	Steel	
	Meter Nut Plug	Black Cast Iron	ASTMA126 Class B
	O-Ring Gasket	Buna-N	Suitable for use with natural, manufactured and L.P. Gases
	Dielectric/Insulation	Nylon	Dielectric strength meets and exceeds industry standards

Wal-Rich Part #	L	Inlet Size	Outlet Size	Tap Size	Swivel Size	Weight (lbs.)
0423002	6"	1"	1"	20LT	1/8"	7.50